

DFES – DBA Fire Alarm Monitoring ASE III Terminal Strip

- ASE** – Alarm Signalling Equipment
- ASE COMMON** – To be connected to COM on FIP Relay Outputs used for signaling
- DBA** – Direct Brigade Alarms
- DFES** – Department of Fire & Emergency Services of WA
- FIP** – Fire Indicator Panel
- Fire Agent** – Personnel Servicing Fire Detection System (Customer Equipment) FIP, Sprinkler, ect
- LPE** – Lightning Protection Earth – See Section 3.3 of DFES DBA Standards
- LWP** – Low Water Pressure
- Secondary PSTN** – Back Up Telephone Line
- SIP** – Sub Indicator Panel
- SPARE** – Spare Input

ASE III MANDATORY TERMINAL STRIP

Fire Agent Side
Customer Side

DFES Side

⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕
⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕
LPE	PSTN	Secondary	ASE COMMON	ALARM	FAULT	ISOLATE	SPARE	SPARE	SPARE	+ 27 Vdc	NEGATIVE

ASE III AVAILABLE TERMINALS

Fire Agent Side
Customer Side

DFES Side

⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	
⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	⊕	
LPE	PSTN	Secondary	ASE COMMON	ALARM	FAULT	ISOLATE	SPRINKLER	GAS	SIP	V. TAMPER	LWP	TANK LOW	PANEL BATTERY	PUMP RUN	PUMP FLT	+ 27 Vdc	NEGATIVE

		DWG Title	
		CodeRed ASE III	
		Terminal Strip	
		DWG NO. CCR2010DO0001	
DRAWN	Denis Orozovic	DATE	19/08/2010
CHECKED	Denis Orozovic	DATE	12/02/2014
APPROVED		DATE	
		JOB NO.	261V
		REV NO.	3.0
		SHEET	1 OF 1
		REV DATE	12/02/2014
		FILE	